



74 Kent Street  
Brooklyn, New York 11222-1517

Phone (718) 383-5080  
Fax (718) 383-7445  
E-mail: dllabs@aol.com

Accredited by National Voluntary Laboratory Accreditation Program - Lab Code 100252  
ISO / IEC 17025 and relevant requirements of ISO 9002

March 16, 2005

United Coatings  
19011 Cataldo Avenue  
Spokane Valley, WA 99016

Att: **Mr. Mike Sand**

**DL-14450B**  
**Via FAX (509) 928-1116**

### **OBJECTIVE**

To evaluate submitted test assemblies coated with a waterproofing material for crack bridging.

### **PRODUCT TESTED**

The test assemblies were submitted by United Coatings and the waterproofing membrane identified as Elastuff 300.

### **TEST PROCEDURE**

Testing was conducted in accordance with procedures outlined in Par. 5.7.4, Low-Temperature Flexibility and Crack Bridging of ASTM C 836.

### **CONCLUSION**

The waterproofing material did not exhibit any cracking or loss of adhesion after completion of 10 cycles of movement.

**DL Labs, Inc.**

A handwritten signature in black ink, appearing to read 'Thomas J. Sliva'.

Thomas J. Sliva  
Vice President/  
Technical Director

mb

cc: M. Lazaro, Jr.